

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0900:133

Page 1 of 1

CATEGORY: Annunciators

LISTEE: Fike Protection Systems, 704 S. 10th St., Blue Springs MO 64015
Contact: Kevin Montgomery (816) 229-3405 FAX (816) 229-5082

DESIGN: Models GP-5RA Remote Zone Annunciator and GP-10RA Remote Fire Annunciator.
Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The GP-5RA is intended to be installed on a standard listed single gang electrical back box. The GP-10RA is intended to be installed on a three gang electrical back box.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as remote annunciators for use with listee's separately listed electrically and functionally compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLf: 7120-0075:171

01-23-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager